



ALASKA RAILROAD CORPORATION
327 W. Ship Creek Ave.
Anchorage, AK 99501.

April 13, 2020

Addendum 3

ITB # 20-13-207520

BUILDING 26 INDUSTRIAL WATER UPGRADES

This ITB will close as follows:

Proposals will be received until Wednesday, April 15, 2020 @ 3:00 PM local Alaska time.

QUESTIONS

1. Spec section 22 07 00 paragraph 3.2 requires us to install an 8 gauge insulation shield. This seems excessive. Please see the attached Pipe shield submittal, this is what would normally be used. Take note of the "approvals" section. Perhaps the specification could just reference some of those approvals.

Provide a shield, not less than 12" long of 18 gauge galvanized steel, 180 degree segments between piping support and hanger. Shield shall be permanently attached to hanger.

If there are any questions regarding this addendum please let me know.

Thank you,

Candice Humphrey
Procurement Administrator
Alaska Railroad Corporation

Enclosure:

April 7, 2020 Pre-Bid Site Visit Attendees List

ALASKA RAILROAD

SOLICITAION: ITB #20-13-207520

PRE-BID (2) SIGN IN SHEET

TITLE: Building 26 Industrial Water Upgrades

DATE: April 7, 2020

(PLEASE PRINT CLEARLY)

COMPANY NAME	CONTACT NAME	PHONE	E-MAIL
ARRC- Procurement	Candice Humphrey	907-502-0007	HumphreyC@akrr.com
ARRC- Projects/Engineering	Jacob Kern	907-265-2520	KernJ@akrr.com 
ARRC			
Alaska Mechanical Inc.	Dan Talbert	907-982-7394	DTalbert@ami-alaska.com
Norcoast Mechanical, Inc.	Steve Cox	907-562-2125	Steve@norcoastmecanical.com
Ameresco	JERRY MIKOS	907-444-7666	
Ameresco	JONATHAN CARTER		
Alaska Mechanical Inc	Dan Talbert	907-982-7394	DTalbert@AMI-Alaska.com
CLC Services	Matt Klebs	907-440-4212	Matt@CLCServicesAla.com

PLEASE PRACTICE SOCIAL DISTANCING AND REMAIN 6 FEET AWAY FROM OTHERS AT ALL TIMES

PPE REQUIRED